



**INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSZAWA
tel.: +48 (22) 57 96 167, +48 (22) 57 96 168
e-mail: certification@itb.pl, www.itb.pl



**NATIONAL CERTIFICATE
OF CONSTANCY OF PERFORMANCE
No 020-UWB-2958/W**

In compliance with the Ordinance of the Minister of Infrastructure and Construction of 17 November 2016 on the Way of Declaring Performance of Construction Products and Way of Labelling Them with The Construction Mark (Journal of Laws 2016, item 1966, as amended) this certificate applies to the construction product:

**Internal steel fire resisting or fire resisting and smoke control
doors DTS-PP30, DTS-PP30-2, DTS-PP60 and DTS-PP60-2
of the PORTA system with the option of use on escape routes**

general identification, intended use and performance of the product are described
in the Annex No. Z-020-UWB-2958/W
which is an integral part of this certificate

covered by the Product Polish Standards:

PN-EN 16034:2014-11

PN-EN 14351-2:2018-12

placed on the market under the name or trade mark of:

**PORTA KMI POLAND S.A.
ul. Szkolna 54
84-239 Bolszewo
Poland**

and produced in the manufacturing plant:

**PORTA KMI POLAND S.A. w Bolszewie Oddział w Elku (PKM)
ul. Strefowa 6/8, 19-300 Elk
Poland**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance which refer to declared performances of the product related to its intended use defined in this certificate, under national system 1 are applied and that

the producer has implemented the factory production control system to ensure maintaining the constancy of these performances.

Certificate No 020-UWB-2958/W was first issued on 04.07.2022. This certificate (updated on 17.08.2022, 26.05.2026, 24.07.2026) will remain valid as long as neither the Polish Standard applied, the AVCP methods, the construction product nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the accredited product certification body.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



Warsaw, 24.07.2026

DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.



Annex No. Z-020-UWB-2958/W, page 1/6
which is an integral part of the certificate No. 020-UWB-2958/W

Internal steel fire resisting or fire resisting and smoke control doors DTS-PP30, DTS-PP30-2, DTS-PP60 and DTS-PP60-2 of the PORTA system with the option of use on escape routes

Essential characteristics of the product ¹⁾	PN-EN 16034:2014-11	Performance
Resistance to fire	4.1	El ₂ 30
		El ₁ 30 / El ₂ 60
Smoke control	4.2	S _{a4} , S ₂₀₀
Self-closing	4.4	C

Essential characteristics of the product ¹⁾	PN-EN 14351-2:2018-12	Performance
Ability to release	4.10	Fulfilled (EN 1125)

Declared intended use of the product:

Internal, hinged, steel, single- and double-leaf, rebated, solid or with glazing doors:

- ✓ Single-leaf DTS-PP30 and double-leaf DTS-PP30-2 with fire resistance: El₂ 30
 - ✓ Single-leaf DTS-PP30 and double-leaf DTS-PP30-2 with fire resistance and smoke control: El₂ 30 - S_{a4}, S₂₀₀
 - ✓ Single-leaf DTS-PP30 and double-leaf DTS-PP30-2 with fire resistance and self-closing: El₂ 30 - C
 - ✓ Single-leaf DTS-PP30 and double-leaf DTS-PP30-2 with fire resistance, smoke control and self-closing: El₂ 30 - S_{a4}, S₂₀₀ - C
 - ✓ Single-leaf DTS-PP60 and double-leaf DTS-PP60-2 with fire resistance: El₁ 30 / El₂ 60
 - ✓ Single-leaf DTS-PP60 and double-leaf DTS-PP60-2 with fire resistance and smoke control: El₁ 30 / El₂ 60 - S_{a4}, S₂₀₀
 - ✓ Single-leaf DTS-PP60 and double-leaf DTS-PP60-2 with fire resistance and self-closing: El₁ 30 / El₂ 60 - C
 - ✓ Single-leaf DTS-PP60 and double-leaf DTS-PP60-2 with fire resistance, smoke control and self-closing: El₁ 30 / El₂ 60 - S_{a4}, S₂₀₀ - C
- intended for use in fire- and smoke compartmentation with the option of use on escape routes.

¹⁾ **Note:** The standard PN-EN 16034:2014-11 shall be applied together with the standard PN-EN 14351-2:2018-12. Regardless of the essential characteristics listed in this certificate, the manufacturer shall declare the performance of the essential characteristics covered by the standard PN-EN 14351-2:2018-12 that are not covered by the scope of the tasks of the accredited certification body and this certificate.

HEAD
of the Certification Department



Katarzyna Hatowska, M.Sc. Eng.



Warsaw, 24.07.2026

DEPUTY DIRECTOR
of Instytut Techniki Budowlanej



Anna Panek, M.Sc. Eng.



INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168
e-mail: certification@itb.pl, www.itb.pl

CERTIFICATION MARK

The company:

PORTA KMI POLAND S.A.
ul. Szkolna 54
84-239 Bolszewo
Poland

being the manufacturer of the products:

**Internal steel fire resisting or fire resisting and smoke control
doors DTS-PP30, DTS-PP30-2, DTS-PP60 and DTS-PP60-2
of the PORTA system with the option of use on escape routes**

is authorized to use
the ITB certification mark „WYRÓB BUDOWLANY”
during the period of validity of the certificate no. 020-UWB-2958/W



020-UWB-2958/W

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



Warsaw, 24.07.2026

DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.